


LOCATION 4005 Brookstone Ct. CITY Easton, Va
 BETWEEN Silver Creek STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	1/2	Plastic	85'	10/18/01		
MAIN TO PROP LINE	1/2	Plastic	5'			
PROP LINE TO BLDG	1/2	Plastic	80'			

 ENTERS 4007 Brookstone Ct BRANCHED INTO 4005 Brookstone Ct.
 TAP SIZE 3/4 3 way PRESSURE 60 PSI _____ INCHES W C LOCATION 19' W of C of Brookstone Ct.
P. Tee
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY NL
Service 3/4 C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994
 DEPTH 2 FT 0 IN LOCATION 270' W of C of Silver Creek
 "A" P/S READING Plastic w/1A TOTAL ANODES 1# 0 17# 0 LR # 181554
 REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead White Existing Main	E	

Reser
Plastic (Galv.)

COPY