

LOCATION 939 Brown St.CITY GASTONIABETWEEN McguireSTREET & Craven

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>4' used to</u>	<u>1-8-92</u>		
MAIN TO PROP. LINE			<u>tie over Existing</u>			
PROP. LINE TO BLDG.			<u>Plastic</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 247 East ofcenter of McGuirePRESSURE TEST: @ 100 psi For 1/4 Hrs. By R HayesMAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991DEPTH: 3 Ft. _____ In. LOCATION 14 South of center of Brown"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY