

LOCATION 1011 Brown St. CITY GASTONIA
BETWEEN Arkway St. STREET & Jenkins Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>4'</u>	<u>1-2-92</u>	<u>Tied over</u>	<u>64' of Existing</u>
MAIN TO PROP. LINE					<u>3/4 PLASTIC</u>	<u>to 4" MAIN</u>
PROP. LINE TO BLDG.						

ENTERS: 1011 Brown St BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 16' S of C of Brown St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 2 Ft. 6 In. LOCATION 121' W of C of Arkway St.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY