

LOCATION 1951 BROWNSTONE CT CITY GASTONIA  
BETWEEN Yellowstone STREET & MOSS CT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	Plastic	112'	3/3/95		
MAIN TO PROP. LINE	3/4'		40'			
PROP. LINE TO BLDG.	3/4'		72'			

ENTERS: 1951 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION South side of 1951


PRESSURE TEST: @ 100 psi For 44 Hrs. By DT

MAIN-SIZE 2' C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1988

DEPTH: 2 Ft. 6 In. LOCATION West side of Brownstone

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 065812

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY