


LOCATION 2041 Brown Stone Ct. CITY GASTONIA
BETWEEN Mass Ct. STREET & 2051 Brown Stone Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>169'</u>	<u>6-21-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>47'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>122'</u>			

ENTERS: 2041 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 287' N of C of Mass Ct.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1989
DEPTH: 3 Ft. 0 In. LOCATION 20' W of C of Brownstone Ct.

"A" P/S READING PLASTIC TOTAL ANODES 1* _____ 17* _____ L.R. # _____
REMARKS: New 3/4 Plastic Gas Service with Road Bore.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY