

LOCATION 2050 Brownstone Ct CITY Easton

BETWEEN Moss Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>157</u>	<u>11-10-93</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>6</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>151</u>			

ENTERS: 2050 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Inside House


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Barnett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1988

DEPTH: 2 Ft. 6 In. LOCATION 19' N of c 1st

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # 00447059

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY