

LOCATION	3570 Bryant Cole Way			CITY	Castroville	
BETWEEN	Jordaniway Ln			STREET &	STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	40'	8-29-95		
MAIN TO PROP. LINE	3/4"	P	0			
PROP. LINE TO BLDG.	3/4"	P	40'			

ENTERS: 3570 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 240' W. of center of Jordaniway Ln.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. GUFFEY

MAIN-SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 3 Ft. 0 In. LOCATION 12' N. of center of Bryant Cole Way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 422675

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY