

LOCATION 3525 Bryant Cole way CITY GASTONIA
BETWEEN Jordan View Lane STREET & 3511 Bryant Cole way STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>60'</u>	<u>5-2-94</u>	<u>Existing</u>	<u>Service on</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>0'</u>		<u>3525</u>	<u>Property</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>60'</u>		<u>Already</u>	

ENTERS: 3525 BRANCHED INTO: 3511

TAP SIZE: 3/4 ^{straight} Tee PRESSURE 40 P.S.I. _____ INCHES W.C. LOCATION 145' W of C of Jordan View Lane


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

^{Service} MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 2 Ft. 0 In. LOCATION 62' S of C of Bryant Cole way

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # 176628

REMARKS: Split Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY