

LOCATION 3541 Bryant Cole WayCITY GastoniaBETWEEN Jordan view LnSTREET & Dead end

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	115'	12-8-93		
MAIN TO PROP. LINE	3/4	P	50'			
PROP. LINE TO BLDG.	3/4	P	65'			

ENTERS: 3541BRANCHED INTO: 0TAP SIZE: 1/2

PRESSURE

60

P.S.I.


INCHES W.C.

LOCATION W. Side of 3541PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2"C.I. BARE STEEL COATED STEEL PLASTIC ✓YEAR INSTALLED 1992DEPTH: 3 Ft.

In.

LOCATION 19' N of Bryant Cole Way"A" P/S READING plasticTOTAL ANODES 1* - 17* -L.R. # 489504

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY