

LOCATION 3567 Bryant Cole Way CITY CASTONIA  
BETWEEN Jordanview Lane STREET & MARIA LYNN CT. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>105'</u>	<u>5-3-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>60'</u>			

ENTERS: 3567 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 116' W of E of Jordanview Lane


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. 3 In. LOCATION 19' N of E of Bryant Cole Way

"A" P/S READING P TOTAL ANODES 1\* — 17\* — L.R. # 168873

REMARKS: new Plastic Service with Road Bore



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY