

LOCATION 3599 Bryant Cole way CITY GASTONIA
 BETWEEN GASTON DAY School Rd. STREET & BRYANT Cole way STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>25'</u>	<u>5-27-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>22'</u>			

ENTERS: 3599 BRANCHED INTO: 0
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 87' W of Co of Gaston DAY School Rd.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AL
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992
 DEPTH: 3 Ft. 0 In. LOCATION 18' S of Co of MARIA LYNN CT.

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY