

LOCATION 3615 Bryant Cole Way CITY CASPERIA

BETWEEN MARIA LYNN CT STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>	<u>5-18-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS: 3615 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 100' N. of center of

MARIA LYNN CT.


PRESSURE TEST: @ 150 psi For 1/4 Hrs. By S. HUFFBURN

MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 18' W. of center of Bryant Cole Way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 233098

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY