

LOCATION 3633 Bryant Cole way - Split Service CITY GASTONIA  
BETWEEN MARIA LYNN CT. STREET & Jordanview Lane STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	50'	7-29-94		
MAIN TO PROP. LINE	3/4	Plastic	5'			
PROP. LINE TO BLDG.	3/4	Plastic	45'			

ENTERS: 3625 Bryant Cole way BRANCHED INTO: 3633 Bryant Cole way  
TAP SIZE: 3/4" Straight Tee PRESSURE 60 P.S.I. INCHES W.C. LOCATION 203' N of C of MARIA LYNN CT.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

Service MAIN - SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 2 Ft. 0 In. LOCATION 68' E of C of Bryant Cole way

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. # 322619

REMARKS: New 3/4 Split Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY