

LOCATION 3642 Bryant Cole way

CITY GASTONIA

BETWEEN MARIA LYNN CT.

STREET & Jordan View lane

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	85'	8-3-95		
MAIN TO PROP. LINE	3/4	Plastic	10'			
PROP. LINE TO BLDG.	3/4	Plastic	75'			

ENTERS: 3642

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 140' N of 1st of Maria Lynn Ct.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 20' W of 1st of Bryant Cole way

"A" P/S READING Plastic N/A TOTAL ANODES 1* 17* L.R. # 376357

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY