

LOCATION 3649 Bryant Cole way

CITY GASTONIA

BETWEEN Jordanview Lane

STREET & MARIA LYNN

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	120'	5-27-94		
MAIN TO PROP. LINE	3/4	P	47'			
PROP. LINE TO BLDG.	3/4	P	87'			

ENTERS: 3649

BRANCHED INTO: 3641

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 220' E of C of Jordanview Lane


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 20' S of C of Bryant Cole way

"A" P/S READING P TOTAL ANODES 1\* 17\* L.R. # 212 257

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY