

LOCATION 3697 Bryant Cole Way CITY GASTONIA
BETWEEN Jordanview Lane STREET & MARIA LYNN Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>135'</u>	<u>11-18-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85'</u>			

ENTERS: 3697 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 40 P.S.I. _____ INCHES W.C. LOCATION 46' E of C of Jordanview Lane


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 22' S of C of Bryant Cole Way

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # 508883

REMARKS: New 3/4 Plastic Service with A Road Bore.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY