

LOCATION 3739 BRYANT CDE WAY CITY GASTONIA

BETWEEN JORDANVIEW LN. STREET & CUL-DE-SAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>		<u>1-20-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>				
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>				

ENTERS: 3739 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI          INCHES W.C. LOCATION 230 W of center of

JORDANVIEW LN.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFSTETER

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1982

DEPTH: 3 FT. 0 IN. LOCATION 35' NW. of center of Bryant Cde Way

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 25723

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		