

LOCATION 3765 BRYANT COLE WAY

CITY Gastonia

BETWEEN MARIE LYNN CT

STREET & JORDANVIEW WAY

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	99'	3-18-54		
MAIN TO PROP. LINE	3/4	P	46'			
PROP. LINE TO BLDG.	3/4	P	53'			

ENTERS: 3765 BRYANT COLE WAY

BRANCHED INTO: ✓

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 150' S of JORDANVIEW LN


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Brown

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 22' W of BRYANT COLE WAY

"A" P/S READING 0 TOTAL ANODES 1\* 17\* L.R. # 103408

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY