

LOCATION 4812 Buckeye Ln CITY Gastonia  
BETWEEN Maple Leaf STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>95'</u>	<u>3-30-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>25'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>70'</u>			

ENTERS: Same BRANCHED INTO  
TAP SIZE: 3/4 PRESSURE 60# PSI \_\_\_\_\_ INCHES W C LOCATION 14' South of Center of

Buckeye Ln + 200' East of Maple Leaf


PRESSURE TEST @ 100# PSI FOR 1/4 HRS BY B B

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 6 IN LOCATION 14' South of Buckeye Ln

"A" P/S READING Plastic TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # 215014

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY