

LOCATION 2001 BuckThorne ct. CITY Gastonia
BETWEEN Stone pine Dr. STREET & White Cedar Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>125'</u>	<u>2-27-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>42'</u>	<u>2-27-01</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>83'</u>	<u>2-27-01</u>		

ENTERS 2001 BuckThorne ct. BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 108' East


of center of stone pine DR.
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.R.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3' FT 1" IN LOCATION 13' south of center of BuckThorne ct.

"A" P/S READING 11A TOTAL ANODES 1# Ø 17# Ø LR # 0149597

REMARKS new 3/4" P. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>