

LOCATION 2006 Buckthorne Ct CITY GASTON
 BETWEEN White Cedar Dr STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	89	1/21/00		
MAIN TO PROP LINE	"	"	16			
PROP LINE TO BLDG	"	"	73			

ENTERS 2006 Buckthorne Ct BRANCHED INTO N/A

TAP SIZE 3/8 PRESSURE 60 PSI 3/4 INCHES WC LOCATION East Side of

2006 Buckthorne Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Q. Carr

MAIN SIZE 2 C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 14' South of Center of Buckthorne Ct.

"A" P/S READING N/A TOTAL ANODES 1# - 17# - LR # -

REMARKS Installed New 3/4 plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	