

LOCATION 2013 BUCKTHORNE CT CITY GASTONIA

BETWEEN WHITE CEDAR DR STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
Service MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>70'</u>	<u>8-27-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>60'</u>			

ENTERS 2016 BRANCHED INTO 2013

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 374' S of C of
WHITE CEDAR DR

PRESSURE TEST @ 100 PSI FOR 4 HRS BY P.R.

MAIN-SIZE 3/4 C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2006

DEPTH 2 FT 0 IN LOCATION 34' E of C of BUCKTHORNE CT

"A" P/S READING: plate TOTAL ANODES 1# 0 17# 0 LR # 00649832

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plate</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

