

LOCATION 716 Burton Wood Dr. CITY EASTONIA
BETWEEN Garrison Blvd. STREET & Idle wood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>127'</u>	<u>9-23-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>16'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>111'</u>			

ENTERS: 716 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 396' N of C of Garrison Blvd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1960

DEPTH: 3 Ft. 0 In. LOCATION 17' E of C of Burtonwood Dr.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 512239

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY