

LOCATION 506 Butler ct. CITY Gastonia, N.C.

BETWEEN 12th ave. STREET & Butler St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>63'</u>	<u>5-6-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>4'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>59'</u>	<u>"</u>		

ENTERS 506 BRANCHED INTO Ø

TAP SIZE 5/8" PRESSURE 60 PSI INCHES W C LOCATION 151' south of center of Butler St.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woods

MAIN-SIZE 2" C I Ø BARE STEEL Ø COATED STEEL Ø PLASTIC ✓ YEAR INSTALLED 1996

DEPTH 3' FT 0" IN LOCATION 33' west yard of Butler ct.

"A" P/S READING 114 TOTAL ANODES 1# Ø 17# Ø LR # 00110537

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>114</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>114</u>