

LOCATION 507 Butler CT.

CITY GASTONIA

BETWEEN Butler ST

STREET & Butler CT

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	78' New	8-10-96	8-10-96	
MAIN TO PROP. LINE	3/4	Plastic 5' Existing 17 3/4' Plastic			118' 3/4 P.	
PROP. LINE TO BLDG.	3/4	Plastic	90'			

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 5' West of Butler CT.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 Ft. In. LOCATION 27' South of Butler CT.

"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. #

REMARKS: Retired Service going out the BACK to 1236 Morgan ST. Renewed Service to Butler CT. 2" Plastic Main System Enhancement



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY