

LOCATION 104 Button Bush Ct. CITY Los Angeles

BETWEEN Red Oak St STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>82</u>	<u>8-29-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>7</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>75</u>			

ENTERS: 104 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION E side of house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By J Benett

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 2 Ft. 6 In. LOCATION 33' 8" depth

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # 00371775

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY