

LOCATION 723 Cameron Ave. CITY Gastonia
BETWEEN Doffin Ln. STREET & Pinehurst St. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>110'</u> | <u>8-12-95</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>Plastic</u> | <u>34'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>76'</u> | | | |

ENTERS: 723 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 58' E of C of Pinehurst St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1970

DEPTH: 2 Ft. 0 In. LOCATION 16' W of C of Cameron Ave.

"A" P/S READING 60 TOTAL ANODES 1* 17 * 1 L.R. # 397808

REMARKS: New 3/4 Plastic Service with A Road Bore.



| Test Station | | |
|--|------|----------------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | <u>Riser Plastic</u> |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY