

LOCATION 509 CAMERON POINTE LN CITY GASTON'S
BETWEEN S. NEW HOPE STREET @ DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>75'</u>	<u>3-5-96</u>		
MAIN TO PROP. LINE	<u>1'</u>	<u>1'</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>1'</u>	<u>1'</u>	<u>60'</u>			

ENTERS: 509 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION 20' S. of cap
Cameron Pointe


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY