

LOCATION 534 Cameron Pointe Ln. CITY GASTONIA

BETWEEN S. New Hope Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	126'	2-2-98		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	81'			

ENTERS: 534 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W C LOCATION 826' SW. of center of

S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HOFFER

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 19' SE of center of Cameron Pointe Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY