

LOCATION 538 Cameron Pointe LN. CITY BARTONIA
BETWEEN S. New Hope Rd. STREET & End of Calderack STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>119'</u> | <u>2-25-98</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>Plastic</u> | <u>48'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>71'</u> | | | |

ENTERS: 538 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 918' W of Cof S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH. 4 FT. 0 IN LOCATION 20' S of Cof Cameron Pointe LN.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 117990

REMARKS:



| Test Station | | |
|--|----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Riser</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | <u>Plastic</u> |

ENG. DEPT. USE ONLY