

LOCATION 545 CAMERON POINTE LN. CITY GASTONIA
BETWEEN S. New Hope Rd. STREET & Ceet-de-Sac STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>	<u>4-16-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>68'</u>			

ENTERS: 545 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 1171' SW. of center of
center of S. New Hope Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HURFSTILLER
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED
DEPTH: 3 FT 0 IN. LOCATION 20' S. of center of CAMERON POINTE LN

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 250690

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		