

LOCATION 548 Cameron Pointe Ln. CITY GASTONIA

BETWEEN S. New Hope Rd. STREET & Cat. de Sae STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>124'</u>	<u>2-6-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>79'</u>			

ENTERS: 548 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 20' S. of center of

Cameron Pointe Ln.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HUFFSTADT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED _____

DEPTH: 3 FT 0 IN. LOCATION 1259' SW. of center of S. New Hope Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		