

LOCATION 556 Cameron Pointe LN. CITY GASTONIA
BETWEEN S. New Hope Rd. STREET & End OF Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>120'</u>	<u>2-18-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>70'</u>			

ENTERS: 556 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 1428' w of Cog S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 4 FT 0 IN. LOCATION 23' S of Cog Cameron Pointe. LN.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 059493

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY