

LOCATION 633 Camp Rotary Rd CITY Gastonia

BETWEEN Jake Long Rd. STREET & Jim Torrence Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>86'</u>	<u>12-14-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>76'</u>			

ENTERS 633 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 140' E of center of Jim Torrence Ln.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. G.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 13' N. of center of Camp Rotary Rd.

"A" P/S READING 1.3 TOTAL ANODES I# 0 17# 0 LR# 1070685

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	W	