

LOCATION 2316 Camp Rotary Rd CITY Castroville
BETWEEN Ole Stage Rd STREET & Chapel Grove Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>1'</u>	<u>8-16-96</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2316 BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 105 psi For 1/4 Hrs. By EP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 2 Ft. 0 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1* Q17* Q L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.15/k</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY