

LOCATION 1010 Candlewood DR CITY GASTONIA

BETWEEN Laurel Woods Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>86'</u>	<u>4-22-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>74'</u>			

ENTERS: 1210 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 478' S.W. of center of

Laurel Woods Dr


PRESSURE TEST: @ 100 PSI FOR 10' min HRS BY S. Guller

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION 16' N.W. of center of Candlewood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY