

1 LOCATION 1211 Canollewood Dr CITY GASTON

BETWEEN LAUREL WOODS DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	117'	4-22-97		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	82'			

ENTERS: 1211 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 PSI INCHES W.C. LOCATION 581' SW. of center of

LAUREL WOODS DR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY S. HUBBARD

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 16' NW. of center of Canollewood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 241926

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		