

LOCATION 1215 Candlewood DR CITY CASTONIA

BETWEEN Laurel wood DR STREET & Shady Oak TRL STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	118'	12-3-97		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	83'			

ENTERS: 1215 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 448' N. of center of

Shady Oak TRL.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HUFFSTETTER

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 15' W. of center of Candlewood DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY