

LOCATION 1220 Candlewood Dr CITY Easton

BETWEEN Shady Oak Trl. STREET & Laurel Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	88'	5-2-97		
MAIN TO PROP LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	78'			

ENTERS: 1220 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W C LOCATION 293' W. of center of

Shady Oak Trl.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hufstuf

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 17' SW. of center of Candlewood Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 265367

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY