

LOCATION 1318 Candlewood Dr. CITY SASTONIA
BETWEEN Creekside Dr. STREET & End of Elderack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>110'</u>	<u>9-15-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>100'</u>			

ENTERS 1318 BRANCHED INTO D

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 110' E of Creek View Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 6 IN LOCATION 43' S of Candlewood Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>River</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>Plastic</u>