

LOCATION 1256 CANOBY CT. CITY GASTON, N.C.

BETWEEN BERWILL JLN. STREET & DEVONSHIRE CT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>110'</u>	<u>10.5.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>105'</u>			

ENTERS 1256 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION N. side of house


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY BL

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC / YEAR INSTALLED \_\_\_\_\_

DEPTH 3 FT IN LOCATION E side of and de. 500

"A" P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	