

LOCATION 102 CAPE BRETON TEL. CITY GASTONIA

BETWEEN KELTIC MEADOWS STREET & HALIFAX STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>100'</u>	<u>4-18-95</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>52'</u>			

ENTERS: 102 BRANCHED INTO:       

TAP SIZE: 1/2 PRESSURE 60 P.S.I.        INCHES W.C. LOCATION       


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BJ

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 6 In. LOCATION 133' W OF C OF CAPE BRETON / 22' N OF C OF KELTIC MEADOWS

"A" P/S READING P TOTAL ANODES: 1\* P 17\* P L.R. # 00122651

REMARKS:       



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY