

LOCATION

331 CAPE Breton TRL.

CITY

GASTONIA

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	PLASTIC	350'	5-21-96		
MAIN TO PROP. LINE	3/4	PLASTIC	100'			
PROP. LINE TO BLDG.	3/4	PLASTIC	250'			

ENTERS: 331

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 726' E of Louis Bourg Ct.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 FT. 6 IN. LOCATION 14' N of Cape Breton TRL.

"A" P/S READING PLASTIC TOTAL ANODES 1# 0 17# 0 L.R. # 258218

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser PLASTIC
P/S Pipeline Lead - White Existing Main	E	