

LOCATION 335 CAPE BRETON TRL. CITY CASTONIA  
BETWEEN \_\_\_\_\_ STREET & \_\_\_\_\_ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>131'</u>	<u>04/18/95</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>101'</u>			

ENTERS: 335 BRANCHED INTO: \_\_\_\_\_  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 13' S. of center of  
Driveway

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bj  
Service MAIN SIZE - 3/4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1995  
DEPTH: 3 Ft. 6 In. LOCATION: 549' E of C of CAPE BRETON 13' W of C of

"A" P/S READING P TOTAL ANODES 1\* P 17\* P L.R. # 60172642

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY