

LOCATION

352 Cape Brenton TRL.

CITY Caston

BETWEEN

Igniosh Dr.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	103'	10-3-96		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	68'			

ENTERS:

352

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

756' W. of center

of Igniosh Dr.

PRESSURE TEST:

@

100

psi

For

44

Hrs.

By

S. H. G. Allen

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1995

DEPTH:

3 Ft.

0 In.

LOCATION

13' N. of center of Cape Brenton TRL.

"A" P/S READING

D

TOTAL ANODES


1# 0

17# 0

L.R. #

553270

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E