

LOCATION 358 Cape Breton TRC. CITY GASTONIA

BETWEEN Igonish DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>	<u>2-10-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS: 358 BRANCHED INTO:

TAP SIZE. 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 613' NW. of center of

Igonish DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HOFFMEYER

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT 0 IN LOCATION 12' NE of center of Cape Breton TRC.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 46489

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY