

LOCATION 604 Capella CTCITY GASTONIABETWEEN CARNEI Hills DRSTREET & Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	<u>Relocated</u>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>4</u>		<u>11-29-95</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 604BRANCHED INTO: -TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 132' S. of C ofCapella CTPRESSURE TEST: @ 100 psi For 1/2 Hrs. By SAMAIN SIZE 3/4C.I. -BARE STEEL -COATED STEEL -PLASTIC ✓YEAR INSTALLED 1995DEPTH: 1

Ft.


6

In.

LOCATION

"A" P/S READING PTOTAL ANODES 1# - 17# -L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY