

LOCATION 604 CAPELLA CT CITY GASTON  
BETWEEN Carmel Hills DR. STREET & STREET


|                     | SIZE | TYPE    | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|---------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4" | Plastic | 103'   | 3/4/95    |         |         |
| MAIN TO PROP. LINE  | 3/4" |         | 11'    |           |         |         |
| PROP. LINE TO BLDG. | 3/4" |         | 92'    |           |         |         |

ENTERS: 604 BRANCHED INTO:  
TAP SIZE: 1/2" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION W side of 604

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1992  
DEPTH: 3 Ft. 0 In. LOCATION West side of CAPELLA CT

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 082855

REMARKS:



| Test Station                               |      |       |
|--|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S    |       |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY