

LOCATION 501 CARL ST. CITY PASTONIA
 BETWEEN CARL ST. STREET & BEVERLY ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>64'</u>		<u>7-</u>	<u>17-57</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>34'</u>			

ENTERS: SAME BRANCHED INTO:
 TAP SIZE: 3/4" PRESSURE 100 PSI _____ INCHES W.C. LOCATION 88' from @ of CARL ST.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1957
 DEPTH: 3 FT. 0 IN LOCATION southside of PEARL ST.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY