

LOCATION 720 & 728 Carlton Dr.

CITY BASTONIA

BETWEEN Garrison Blvd.

STREET & Graystone

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	1'	5-21-94	Tied over 170' Existing 3/4	
MAIN TO PROP. LINE					HW ON 728 Carlton	
PROP. LINE TO BLDG.					Tied over 20' Existing 3/4 at an	

ENTERS: 728 Carlton

BRANCHED INTO: 720 Carlton 720 Carlton

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 435' S of Coy Graystone


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By AL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 19' W of Coy Carlton Dr.

"A" P/S READING P TOTAL ANODES 1* 17* L.R. #

REMARKS: Found Existing 3/4 Insulated Dresser & Bonded. Tied Trace Wire off At Tee.

Bare Main Replacement
Program

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	728 Riser 1.0 720 Riser 1.0
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY